



PROVIDE NEW MAIN & STAND BY DUAL DIESEL FIRE PUMPS REPLACING THE EXISTING FIRE PUMPS. PUMP LOCATION SHOWN IS INDICATIVE, CONTRACTOR TO LOCATE THE PUMP WITH 1 METRE CLEARANCES AROUND PUMP ENCLOSURE. ALLOW TO MODIFY PIPEWORK TO SUIT. CONCRETE PLINTH BY BUILDER

PROVIDE NEW OF 2 OFF - 72,000 LITRES FIRE TANK WITH THE SAME FOOT PRINT OF THE EXISTING TANK (APPROXIMATE HEIGHT OF TANK = 4.7m). TOTAL CAPACITY OF 144,000 LITRES REQUIRED FOR THE OPERATION OF TWO HYDRANTS RUNNING SIMULTANEOUSLY.

EXISTING BOOSTER CABINET TO REMAIN. CONTRACTOR TO PROVIDE NEW ELECTRONIC LEVEL INDICATOR FOR FIRE TANKS. REG 129 REQUIRED AS EXISTING BOOSTER SUCTION CONNECTION DO NOT FACE HARD STAND.

ACCESS DOOR REQUIRED FOR HYDRANT & HOSE REEL COVERAGE  
FIRE EXTINGUISHER IN WEATHER PROOF CABINET

PRE-TENDER

Rev	Description	Checked	Date
A	PRE-TENDER ISSUE	MP	08.12.23
B	PRE-TENDER ISSUE	MP	18.12.23

Architect



**BRANDRICK**  
ARCHITECTS  
plans for perfection



**Waterman Group (AUS) Pty Ltd**  
ACN 121 003 334 ABN 46 121 003 334  
60 Park Street, South Melbourne, Victoria 3205 Australia  
t: 03) 9685 9900 f: 03) 9685 9999  
melbourne@waterman-australia.com.au



**YORTA YORTA NATION**  
ABORIGINAL CORPORATION

Project  
YORTA YORTA KNOWLEDGE, RESEARCH AND EXHIBITION CENTRE - STAGE 2  
YYNAC - 37 SCHIER STREET, BARMAH, VIC. 3639

Title  
FIRE PROTECTION SERVICES  
PROPOSED SITE PLAN

Drawn	MB	Date	NOVEMBER 2023
Checked	MP	Scale	1200 @ A1
		Job No	6176.01
Drawing No	<b>F101</b>	Revision	<b>B</b>